

Notification of Event

CR96343 - Legacy Way – Exceedance of Copper and Nitrogen



1. Summary of Event

On the 2nd of January 2020 Transurban received laboratory results from SAS Laboratories indicating that the Legacy Way Water Treatment Plant discharge water quality monitoring results for samples taken on Thursday the 19th of December 2019 recorded an exceedance for Copper (Soluble) as Cu and Total Nitrogen as N as per the table below:

	Water Quality Discharge Limit	Laboratory Results
Copper (soluble) as Cu	0.005mg/L	0.0061mg/L
Total Nitrogen as N	2.1mg/L	2.3mg/L

2. Immediate Actions Taken

The following actions were taken post identification of the event:

- Review of plant process for anomalies
- Resampling of the water treatment plant discharge to assess if a sustained exceedance is occurring
- Notification of event to Department of Environment and Science
- Establishment of an investigation team